

February 12, 2010

TO ALL DEVELOPERS, CONSULTING ENGINEERS AND CONTRACTORS:

**ADDENDUM TO BYRON / GAINES UTILITY AUTHORITY
STANDARD CONSTRUCTION REQUIREMENTS**

The June, 2009 Byron / Gaines Utility Authority Standard Construction Requirements are herein revised as follows:


The formula used to determine allowable leakage that is specified in Section 4.14.03 "Leakage Test" shall be:

$$L = \frac{SD\sqrt{P}}{148,000}$$

This formula is based on an allowable leakage of 10.49 gallons per day, per mile of pipe, per inch of nominal diameter at 150 psi.

This modification to the Standard Construction Requirements is effective immediately.

Byron-Gaines Utility Authority



Daniel Van Dyke, Director